

PUBLIC NOTICE MANDATORY LANGUAGE CODING
Tier 2 violations/ Non-Acute

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

- The PWS NAME, PWS ID TX1650001, failed to meet the minimum treatment technique requirements for the month of **February 2021**. Specifically, our water system had **Low Disinfection Contact Time (CT) for more than four consecutive hours on the following days 2/17/2021 & 2/18/2021.**

Due to the Freezing temperatures and chlorines lowered effectiveness in colder water expected residuals were not as effective in our treatment process. The City Of Midland PSW1650001 has taken the following corrective actions, Chlorine levels where increased at the water plant and flows where lowered to get back into compliance with State Of Texas Contact Time requirement's.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Carl Craigo _____ at 432-685-7260.

Posted /Delivered on: 2/26/2021

