



MFD FIRE MARSHAL'S OFFICE
1500 W. Wall St Midland, TX 79701
432-685-7333

MOBILE FOOD VENDORS

Please have all of the following items completed, prior to inspection.

- All LP-Gas containers (empty or full) shall be secured properly in the upright position on the outside of the vehicle.
- All gas lines are free of leaks at all fittings and appliances.
- All vendors shall carry a (3A-40BC minimum) Fire Extinguisher. In addition, a **Type K**, for grease fire, portable extinguisher shall also be carried when cooking operations produce grease laden vapors. All extinguishers shall have **approved current annual inspection date tags**. If possible, all extinguishers shall be mounted. Vendors which do not cook shall have a minimum 2A-10BC extinguisher only.
- If equipped, all commercial kitchen fire suppression systems shall have approved current licensed inspections as required by the adopted IFC.
- Ventilation hoods shall be kept clean as needed or at the discretion of the Fire Inspector.
- Refueling of generators shall be performed in an approved location not less than 20 feet from the Mobile Food Unit. All fuel shall be stored in a UL or FM listed flammable liquid safety container and in an approved location.
- All 120v electrical wiring shall be installed and maintained according to the National Electrical Code.
- Open wiring and junction boxes are prohibited.
- Overall appearance of the vehicle exterior shall be maintained in good condition
- Vehicle and trailer wiring, lights and signals shall meet DOT standards.