



Daycare Requirements
Fire Marshal Office
1500 W Wall St, Midland, TX 79701
432.685.7333

- Building Occupancy of 50 or more people
 - Alarm System is required. The alarm system must meet state requirements.
 - Any structure greater than 12,000 square feet may be required to install an automatic sprinkler system.
 - Building must have the following inspections completed before opening, followed by an annual inspection (to be kept up with by the facility's owner(s)).

- Cooking Requirements
 - Type 1 Hood
 - Required when cooking equipment can be used to fry on or within.
 - This equipment also requires a protection system most often referred to as an ANSUL system.
 - Type 2 Hood
 - Required for standard and/or small kitchen equipment such as crockpots, microwaves, ovens and toaster ovens.
 - If you are uncertain about the requirements for a particular piece of equipment, or you do not see your piece of equipment listed please contact the Midland Fire Marshal's office.

- ALL buildings must have portable fire extinguisher(s) every 75 feet of travel distance, with a preference that the extinguisher(s) being located by doors/doorways.
 - Extinguisher Type 2A-10BC.